

ORIGINAL

4125

BEFORE THE ARIZONA POWER PLANT
AND TRANSMISSION LINE SITING COMMITTEE



IN THE MATTER OF THE APPLICATION
OF DUKE ENERGY ARLINGTON VALLEY,
L.L.C. IN CONFORMANCE WITH THE
REQUIREMENTS OF ARIZONA REVISED
STATUTES §40-360.03 AND §40-360.06
FOR A CERTIFICATE OF
ENVIRONMENTAL COMPATIBILITY
AUTHORIZING THE CONSTRUCTION
OF A NATURAL GAS-FIRED, COMBINED
CYCLE GENERATING FACILITY
(ARLINGTON VALLEY ENERGY FACILITY
II) NEAR ARLINGTON IN MARICOPA
COUNTY, ARIZONA

Docket No. L-00000P-01-0117

Case No: 0117

**NOTICE OF FILING
DECISION AND ORDER**

The Arizona Power Plant and Transmission Line Siting Committee hereby gives notice of
filing its decision and order, approving the Application of Duke Energy Arlington Valley, L.L.C.
for a Certificate of Environmental Compatibility.

The Decision and Order are in the form attached hereto.

Dated this 15th day of November, 2001.

ARIZONA POWER PLANT AND
TRANSMISSION LINE SITING
COMMITTEE

By: Laurie A Woodall
Laurie A. Woodall, Esq.
Chairman

Pursuant to A.A.C. R14-3-204,
the Original and twenty-five
copies were filed November 15, 2001:

Docket Control
Arizona Corporation Commission
1200 West Washington Street
Phoenix AZ 85007

Arizona Corporation Commission

DOCKETED

NOV 15 2001

DOCKETED BY

mw

AZ CORP COMMISSION
DOCUMENT CONTROL

2001 NOV 15 P 2:44

RECEIVED

COPIES mailed November 15, 2001, to:

Janice M. Alward
Arizona Corporation Commission
1200 West Washington
Phoenix AZ 85007

Thomas H. Campbell, Esq.
Lewis and Roca LLP
40 North Central Avenue
Phoenix AZ 85004-4429
Attorney for Applicant

Neil A.M. Peters
P.O. Box 57
Arlington AZ 85222



218080.1

**BEFORE THE ARIZONA POWER PLANT AND
TRANSMISSION LINE SITING COMMITTEE**

IN THE MATTER OF THE APPLICATION)
OF DUKE ENERGY ARLINGTON VALLEY,)
L.L.C. IN CONFORMANCE WITH THE) Docket No. L-00000P-01-0117
REQUIREMENTS OF ARIZONA REVISED)
STATUTES §40-360.03 AND §40-360.06)
FOR A CERTIFICATE OF)
ENVIRONMENTAL COMPATIBILITY) Case No: 117
AUTHORIZING THE CONSTRUCTION)
OF A NATURAL GAS-FIRED, COMBINED)
CYCLE GENERATING FACILITY)
(ARLINGTON VALLEY ENERGY FACILITY)
II) NEAR ARLINGTON IN MARICOPA)
COUNTY, ARIZONA)

**DECISION OF THE ARIZONA POWER PLANT AND TRANSMISSION
LINE SITING COMMITTEE AND
CERTIFICATE OF ENVIRONMENTAL COMPATIBILITY**

Pursuant to notice given as provided by law, the Arizona Power Plant and Transmission Line Siting Committee ("Committee") held public hearings at the Quality Inn, Phoenix, Arizona on October 15, 2001 and October 16, 2001 in conformance with the requirements of Arizona Revised Statutes Section 40-360, *et seq.*, for the purpose of receiving public comment and evidence, and deliberating on the Application of Duke Energy Arlington Valley LLC ("Duke") for a Certificate of Environmental Compatibility ("Certificate") in the above-captioned case.

The following members or designees of members of the Committee were present for the hearing on the Application:

Laurie A. Woodall

Chairman, Designee for Arizona Attorney General Janet
Napolitano, Office of the Attorney General

Ray Williamson

Designee of the Chairman of the Arizona Corporation
Commission

Arlington Valley Energy Facility II Project
Docket No. L- 00000P-01-0117

Mark McWhirter	Designee for the Director of the Energy Office of the Arizona Department of Commerce
Richard Tobin	Deputy Director, Arizona Department of Environmental Quality
Gregg Houtz	Designee for the Director of the Arizona Department of Water Resources
Hon. Mike Whalen	Appointed Member
Mike Palmer	Appointed Member
Margaret Trujillo	Appointed Member
A. Wayne Smith	Appointed Member
Jeff McGuire	Appointed Member

Thomas Campbell and Michael Denby of Lewis and Roca LLP represented the Applicant. Staff of the Arizona Corporation Commission ("Staff") noticed their intervention as a party, and were represented by Janice Alward. The City of Goodyear and Neil A.M. Peters were granted intervenor status. Neil A.M. Peters appeared pro per. The City of Goodyear did not appear. There were no other interventions or limited appearances.

At the conclusion of the hearing and deliberations, the Committee (i) having received and considered the Application, the appearances of Applicant and each of the intervenors; the evidence, testimony and exhibits presented by Applicant and the intervenors, respectively; and public comments; (ii) being advised of the legal requirements of Arizona Revised Statutes Sections 40-360 to 40-360.13; (iii) upon consideration of the factors identified in Arizona Revised Statutes Section 40-360.06; and (iv) in accordance with A.A.C. R14-213, upon motion duly made

and seconded, voted (10 in favor, 0 opposed) to make the following findings and to grant

Applicant the following Certificate of Environmental Compatibility:

The Committee finds that the record contains substantial clear and convincing evidence regarding the need for an adequate, economical and reliable supply of electric power and how Applicant's proposed Arlington Valley Energy Facility II (AVEF II) would contribute towards satisfaction of such need without causing material adverse impact to the environment.

Duke, and its assignee(s), are hereby granted this Certificate of Environmental Compatibility authorizing construction and operation of a 600-megawatt (nominal) gas turbine/steam turbine combined-cycle merchant power plant, the key elements of which include two combustion turbine generators with inlet chilling-fueled by pipeline-quality natural gas, two natural gas supplementary-fired Heat Recovery Steam Generators, one steam turbine generator set, one gas-fired (intermittent) auxiliary boiler, one surface condenser, and two mechanical draft cooling systems, together with related infrastructure, including a 500kV switchyard of ring bus design, capable of accommodating four terminals, and upgradable to a breaker and one-half design, which shall be located in Maricopa County, approximately 0.7 miles southwest of the intersection of Elliot Road and Wintersburg Road (the "Project").

This Certificate is granted upon the following conditions:

1. The Applicant will comply with all existing applicable air and waste pollution control standards and regulations, and with all existing applicable ordinances, master plans and regulations of the State of Arizona, Maricopa County, the United States, and any other governmental entities having jurisdiction, including but not limited to the following:

- a. all zoning stipulations and conditions, including but not limited to the landscaping and dust control requirements and/or approvals;

Arlington Valley Energy Facility II Project
Docket No. L- 00000P-01-0117

- b. all applicable air quality control standards, approvals, permit conditions and requirements of the Maricopa County Air Quality Control District and/or other State or Federal agencies having jurisdiction, and the Applicant shall install and operate selective catalytic reduction and catalytic oxidation technology at the level determined by the Maricopa County Air Quality Control District and approved by EPA Region IX. The Applicant shall operate its project so as to meet a 2.5 ppm NOx emissions level, within the parameters established in the Title V and PSD air quality permits issued by the Maricopa County Air Quality Control District for the plant. If technically and economically feasible, Applicant shall install and operate catalytic oxidation technology that will produce a carbon monoxide (CO) and volatile organic compound (VOC) emission rate equivalent to California's current best available control technology (BACT) standard.
- c. all applicable water use requirements of the Arizona Department of Water Resources, and Phoenix Active Management Area, including but not limited to development plan approval, certificate of irrigation grandfathered rights, and applicable management plans;
- d. all applicable water quality and disposal requirements of the Arizona Department of Environmental Quality regulations;
- e. all applicable noise control standards, and during normal operations the Project shall not exceed applicable (i) HUD or EPA residential noise guidelines or (ii) OSHA worker safety noise standards;
- f. all applicable regulations and permits governing storage and handling of chemicals.

2. This authorization to construction AVEF II will expire upon five (5) years from the date this Certificate is approved by the Arizona Corporation Commission ("Commission") unless construction is completed to the point that the facility is capable of operating at its rated capacity; provided, however, that prior to such expiration Applicant or its assignee may request that the Commission extend this time limitation.

3. Applicant will submit to the Commission an interconnection agreement with the transmission providers with whom it is interconnecting before commencing commercial operation.

4. Applicant or its affiliate company will become a member of the Western Systems Coordinating Council ("WSCC") (or its successor), and file a copy of its WSCC Reliability Criteria Agreement or Reliability Management System (RMS) Generator Agreement with the Commission.

5. Applicant will use reasonable efforts to become a member of the Southwest Reserve Sharing Group (or its successor) if commercially reasonable and if involved in the selling of wholesale power to a commercially identifiable load, thereby making Applicant's units available for reserve sharing purposes, subject to competitive pricing.

6. Subject to the Federal Energy Regulatory Commission rules and tariffs and WSCC RMS requirements, Applicant shall commit to offer as ancillary services a total 7% of its total plant capacity to the local Control Area with which it is interconnected and to Arizona's regional ancillary service market once a Regional Transmission Organization is operational, and until such time that a Regional Transmission Organization is operational, to a regional reserve sharing pool.

7. Applicant shall make commercially reasonable efforts to execute wholesale power sales to credit worthy Arizona load-serving entities serving Arizona load and to marketers providing service to those Arizona load serving entities.

Arlington Valley Energy Facility II Project
Docket No. L- 00000P-01-0117

8. The Applicant shall file deed restrictions limiting the use of its property within a .50 mile radius of the generation facility (AVEF II) to non-residential uses so long as AVEF II is operational.

9. From the period beginning 30 days from the date a Certificate of Environmental Compatibility is approved by the Commission, continuing until the generation facility's construction has been completed, Applicant, subject to applicable county regulations, shall erect and maintain at the project site a sign of not less than 15 feet by 10 feet dimensions or of a size at the maximum dimensions for such signs permitted by the local governmental authority, advising:

- that the site has been approved for the construction of a 600 megawatt generating facility
- the expected date of completion of the facility
- if the facility is not timely completed pursuant to the Certificate of Environmental Compatibility, the Applicant would have to seek an extension of the certificate or again pursue approval from the Power Plant Line Siting Committee before it could construct the project. This would afford persons residing in the project's vicinity an opportunity to express their viewpoint through public comment and/or by formally intervening in the application approval process.

10. Where feasible, Applicant shall make commercially reasonable efforts to invite, and shall give full consideration to, bids from qualified local and in-state construction subcontractors for construction of the Project.

11. The Applicant shall operate its evaporation pond so that any salt residue contained therein shall not cause damage to crops grown on fields adjacent to the Project site.

12. Applicant shall use a zero discharge system for its cooling water, subject to existing regulatory requirements.

13. Applicant shall use low profile structures, moderate stacks, neutral colors, compatible landscaping and low intensity directed lighting for the plant. Applicant shall use non-reflective conductors and towers.

14. Applicant shall implement a Land Management Plan that includes:

- (i) Installation of a professionally designed landscape plan for the entrance of the facility and along both sides of Elliot Road.
- (ii) A comprehensive revegetation program that will restore a large portion of the property with plant communities similar to the adjacent desert lands.
- (iii) A partnership with The Arizona Game and Fish Department to provide enhanced wildlife habitat on lands that border Centennial Wash.
- (v) An annual report (for six years) submitted to the Arizona Corporation Commission setting forth the status of the Land Management Plan.
- (v) Including Mr. Neil A.M. Peters, intervenor, and other interested parties, in implementation discussions and shall keep them informed of all aspects of the land management plan.

15. Applicant will convene a workshop in early 2002 to address gas transportation reliability and capacity issues, both short term and long term. Participants will include other Arizona gas-fired power plant owners and wholesale gas transportation providers. The initial workshop will identify issues and establish a timeline for producing a report to the Arizona Corporation Commission in 2002. This topic will be reviewed in subsequent workshops

convened by the Applicant in 2003 and 2004. These workshops will allow for public participation.

16. Once construction commences on the Project, Applicant will pay up to \$11,000,000 for the upgrades to the North Gila and Kyrene transmission lines set forth in the Report on the Preliminary Study for the Palo Verde Interconnection prepared for the Palo Verde Interconnectors and Western Arizona Transmission System Task Force, dated February 20, 2001 (the "WATS Study") at pages 29-31. Applicant will contact the transmission owners of the upgraded lines to determine the earliest opportunity for the transmission lines to be upgraded and Applicant will use commercially reasonable efforts to assure that such upgrades are completed before AVEF II is in commercial operation.

17. Applicant shall participate in good faith in state and regional transmission study forums, such as the Central Arizona Transmission Study, to terminate a second transmission line out of the Arlington Valley Energy Facility that serves the transmission system grid needs to deliver power throughout the Western Systems Coordinating Council grid in a reliable manner. Applicant shall take all commercially reasonable efforts to ensure that such transmission line shall be timely constructed in accordance with the needs of the integrated transmission grid, although Applicant is not required by this Decision to build, finance, operate or own such transmission line.

18. Applicant shall construct a 500kV switchyard of ring bus design and capable of accommodating four terminals and upgradable to a breaker and one-half design if so required by local regional reliability criteria. Two of the terminals will be used to connect to the phases of the

Arlington Valley Energy Facility II Project
Docket No. L- 00000P-01-0117


Applicant's project designated as AVEF I and AVEF II each consisting of 600 MW of generation. The remaining two terminals will provide for connection to the transmission grid, *i.e.*, one for the transmission connection currently under construction to the Hassayampa switchyard associated with AVEF I and one for a future transmission line to be terminated elsewhere. The switchyard shall be of conventional open air design consisting of high voltage power circuit breakers, disconnect switches, grounding switches, potential transformers, surge arrestors, steel structures and protective relaying. Nothing in this order precludes Applicant from seeking reimbursement for these switchyard costs from future users of the switchyard. Applicant shall file a late-filed exhibit describing the switchyard, including its location and a diagram of the facility.

19. Applicant's Project shall be designed and constructed to accommodate two transmission lines emanating from its power plant's transmission switchyard and interconnecting with the existing transmission system. One of these will interconnect with the Hassayampa 500 kV switchyard. This plant interconnection must satisfy the single contingency outage criterion (N-1) after the second transmission line interconnecting with the transmission grid is complete, without reliance on remedial action such as generator unit tripping or load shedding.

GRANTED this ____ day of Nov, 2001.

ARIZONA POWER PLANT AND
TRANSMISSION LINE SITING COMMITTEE

By


Laurie A. Woodall, Chairman

Arlington Valley Energy Facility II Project
Docket No. L- 00000P-01-0117

APPROVED BY ORDER OF THE ARIZONA CORPORATION COMMISSION

Commissioner

Commissioner

Commissioner

IN WITNESS WHEREOF, I, Brian C. McNeil, Executive Secretary of the Arizona Corporation Commission set my hand and caused the official seal of this Commission to be affixed, this ____ day of _____, 2001.

Brian C. McNeil
Executive Secretary

Dissent: _____